

Reference Number:

EICRCOUNTYBRIDGE001

ELECTRICAL INSTALLATION CONDITION REPORT

(REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS7671 (IET WIRING REGULATIONS))

Details of the Client

1

Details of the Client:

COUNTY BRIDGE CLUB
ST OSWALD RD
LEICESTER

LE3 6RJ

Reason for producing the report:

Conformation of compliance with BS7671

Details of the Installation

2

Occupier and Address:

COUNTY BRIDGE CLUB
ST OSWALD RD
LEICESTER

LE3 6RJ

Description of premises:

Commercial

Estimated age of wiring system(years):

12

Evidence of additions / alterations:

No

If yes, estimate
age: (years)Installation records
available:

No

Date of last inspection:

NA

Extent and Limitations of Inspection and Testing

3

Extent of installation covered by this report:

ALL FIXED WIRING AND BONDING

Agreed and operational limitations on inspection and testing (include reasons and person agreed with):

NONE

The inspection and testing detailed in this report and accompanying schedules has been carried out in accordance with BS7671:2008 (IET Wiring Regulations) as amended to **No.3 - January 2015**. Cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have not been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

Summary of the Condition of the Installation

4

See page 2 for a summary of the general condition of the installation in terms of electrical safety.

Overall assessment of the installation in terms of it's suitability for continued use*:

satisfactory

*An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified.

Declaration

5

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations listed above.

Inspected and Tested by:

Name:

A SOUTH

Position:

ENGINEER

Date:

24/06/2019

Signature:

**Report reviewed and authorised for Issue by:**

Name:

A SOUTH

Position:

ENGINEER

Date:

24/06/2019

Signature:



Reference Number:

EICRCOUNTYBRIDGE001

Details of the Contractor Responsible for the Inspection and Testing

6

Company and Address including postcode:

COMPASS ELECTRICS
THE HOLLIES
8 MAIN ST
KIRBY MUXLOE

LE92AL

Telephone Number:

01162 393331

CPS Provider:

STROMA

CPS Registration No:

STRI17932

Recommendations

7

Where the overall assessment of the suitability of the installation for continued use on page 1 is stated as 'UNSATISFACTORY', I/We recommend that any observations classified as 'Code 1 - Danger Present' or 'Code 2 - Potentially dangerous' are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Code FI - Further Investigation Required'. Observations classified as 'Code 3 - Improvement recommended' should be given due consideration.

General condition of the installation in terms of electrical safety:

GOOD

Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested after an interval not exceeding:

5 YEARS

Supply Characteristics & Earthing Arrangements

8

System Earthing Arrangement:

TN-C-S

No. & Type of Live Conductors:

a.c. 3 phase - 4 wire

Other Sources of Supply

(to be detailed on attached schedules)

Supply

Polarity

✓

Nominal Voltage⁽¹⁾U₀

230

V

U

V

Supply Protective Device

Nominal Frequency, f⁽¹⁾

50

Hz

BS(EN):

88-2

Type:

HRC

External Loop Impedance, Z_e⁽²⁾

.0.14

Ω

⁽¹⁾ By Enquiry

Rating:

160

A

Breaking capacity:

1

kA

Prospective Fault Current, I_{pf}⁽²⁾

1.8

kA

⁽²⁾ By Enquiry or by measurement

Particulars of the Installation

9

Maximum Demand (Load)

120

A

Fault Protection:

ADS

Main Switch or Circuit-breaker

Means of Earthing

Distributors Facility:

✓

Installation Earth Electrode:

Type:

Location:

Resistance to Earth:

Ω

Electrode Details (if applicable)

Location:

DB1

BS(EN):

60947

Type:

Current Rating:

200

A

No. of poles:

3

Voltage Rating:

400

V

RCD Operating current

RCD Rated time delay

RCD Operating time at I_{Δn}

mA

ms

ms

Main Protective Conductors

Earthing Conductor:

Material

Copper

Csa:

25

mm²

Continuity & Connection

✓

Other Bonded Services:

Water:

✓

Oil:

✓

Main Protective Bonding Conductor:

Material

Copper

Csa:

10

mm²

Continuity & Connection

✓

Gas:

✓

Steel:

✓

Other:

Reference Number:

EICRCOUNTYBRIDGE001

Inspection Schedule (1)

✓ : Acceptable condition. C1 or C2 : Unacceptable condition. C3 : Improvement recommended.
 N/V : Not verified. LIM : Limitation. N/A : Not applicable. FI : Further investigation

1 - DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT

Comments	Outcome
Condition of service cable	✓
Condition of service head	✓
Distributor's earthing arrangements	✓
Meter tails - Distributor/Consumer	✓
Metering equipment	✓
Isolator	✓

2 - PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES

Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A
Adequate arrangements where a generating set operates in parallel with the public supply	N/A

3 - AUTOMATIC DISCONNECTION OF SUPPLY

Main Earthing / Bonding arrangements:

Presence of distributor's earthing arrangement or earth electrode arrangement •	✓
Adequacy of earthing conductor size •	✓
Adequacy of earthing conductor connections •	✓
Accessibility of earthing conductor connections •	✓
Adequacy of main protective bonding conductor sizes •	✓
Adequacy and location of main protective bonding conductor connections •	✓
Accessibility of all protective bonding connections •	✓
Provision of earthing / bonding labels at all appropriate locations •	✓
FELV	N/A

4 - OTHER METHODS OF PROTECTION (Where the methods listed below are employed details should be provided on separate sheets)

Non-conducting location	N/A
Earth-free local equipotential bonding	N/A
Electrical separation	N/A
Double insulation	✓
Reinforced insulation	✓

5 - DISTRIBUTION EQUIPMENT

Adequacy of Working space / accessibility to equipment	✓
Security of fixing	✓
Condition of insulation of live parts	✓
Adequacy / security of barriers	N/A
Condition of enclosure(s) in terms of IP rating etc	✓
Condition of enclosure(s) in terms of fire rating etc	✓

Reference Number:

EICRCOUNTYBRIDGE001

Inspection Schedule (2)

5 - DISTRIBUTION EQUIPMENT (Continued)

	Comments	Outcome
Enclosure not damaged / deteriorated so as to impair safety		✓
Presence and effectiveness of obstacles		✓
Placing out of reach		N/A
Presence of main switch(es), linked where required		✓
Operation of main switch(es) (functional check)		✓
Manual operation of circuit-breakers and RCD(s) to prove disconnection		✓
Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check)		✓
RCD(s) provided for fault protection - includes RCBOs		✓
RCD(s) provided for additional protection where required - includes RCBOs		✓
Presence of RCD quarterly test notice at or near equipment where required		✓
Presence of diagrams, charts or schedules at or near equipment where required		✓
Presence of non-standard (mixed) cable colour warning notice at or near equipment where required		✓
Presence of alternative supply warning notice at or near equipment where required		✓
Presence of next inspection recommended label		✓
Presence of other required labelling (Please specify)		✓
Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing and overheating)		✓
Single-pole switching or protective devices in line conductors only		✓
Protection against mechanical damage where cables enter equipment		✓
Protection against electromagnetic effects where cables enter ferromagnetic enclosures		✓

6 - DISTRIBUTION CIRCUITS

Identification of conductors		✓
Cables correctly supported throughout their run		✓
Condition of insulation of live parts		✓
Non-sheathed cables protected by enclosure in conduit, duct or trunking		✓
Suitability of containment systems for continued use (including flexible conduit)		
Cables correctly terminated in enclosures		✓
Confirmation that ALL conductor connections, including to busbars, are correctly located in terminals and are tight and secure		✓
Examination of cables for signs of unacceptable thermal and mechanical damage / deterioration		✓
Adequacy of cables for current-carrying capacity with regard for the type and nature of installation		✓
Adequacy of protective devices; type and rated current for fault protection		✓

Reference Number:

EICRCOUNTYBRIDGE001

Inspection Schedule (3)

6 - DISTRIBUTION CIRCUITS (Continued)

	Comments	Outcome
Presence and adequacy of circuit protective conductors		✓
Coordination between conductors and overload protective device		✓
Cable installation methods / practices with regard to the type and nature of installation and external influences		✓
Where exposed to direct sunlight, cable of a suitable type		✓
Cables concealed under floors, above ceilings, in walls / partitions less than 50mm from a surface, and in partitions containing metal parts:		
Cables installed in prescribed zones (see <i>Extent and limitations</i>) •		✓
Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see <i>Extent and limitations</i>) •		✓
Provision of fire barriers, sealing arrangements and protection against thermal effects		✓
Band II Cables segregated / separated from band I cables		✓
Cables segregated / separated from non-electrical services		✓
Condition of circuit accessories		✓
Suitability of circuit accessories for external influences		✓
Single-pole switching or protective devices in line conductors only		✓
Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment - identify / record numbers and locations of items inspected		✓
Presence, operation and correct location of appropriate devices for isolation and switching		✓
General condition of wiring systems		✓
Temperature rating of cable insulation		✓

7 - FINAL CIRCUITS

Identification of conductors		✓
Cables correctly supported throughout their run		✓
Condition of insulation of live parts		✓
Non-sheathed cables protected by enclosure in conduit, ducting or trunking		✓
Suitability of containment systems for continued use (including flexible conduit)		✓
Adequacy of cables for current-carrying capacity with regard for the type and nature of installation		✓
Adequacy of protective devices; type and rated current for fault protection		✓
Presence and adequacy of circuit protective conductors		✓
Co-ordination between conductors and overload protective devices		✓
Wiring system(s) appropriate for the type and nature of the installation and external influences		✓

Reference Number:

EICRCOUNTYBRIDGE001

Inspection Schedule (4)

7 - FINAL CIRCUITS (Continued)

Cables concealed under floors, above ceilings, in walls / partitions	Comments	Outcome
installed in prescribed zones (see <i>Extent and limitations</i>) •		✓
incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage from nails, screws and the like (see <i>Extent and limitations</i>) or		✓
Provision of additional protection by 30mA RCD		
*for circuits used to supply mobile equipment not exceeding 32A rating for use outdoors •		✓
*for all socket outlets of rating 20A or less unless exempt •		N/A
*for cables concealed in walls at a depth of less than 50mm •		N/A
*for cables concealed in walls/partitions containing metal parts, regardless of depth •		✓
Provision of fire barriers, sealing arrangements and protection against thermal effects		✓
Band II cables segregated / separated from band I cables		✓
Cables segregated / separated from non-electrical services		✓
Termination of cables at enclosures - identify / record numbers and locations of items inspected		
Connections under no undue strain •		✓
No basic insulation of a conductor visible outside enclosure •		✓
Connections of live conductors adequately enclosed •		✓
Adequately connected at point of entry to enclosure (glands, bushes etc) •		✓
Condition of accessories including socket-outlets, switches and joint boxes		✓
Suitability of accessories for external influences		✓
Single pole switching or protective devices in line conductors only		✓

8 - ISOLATION AND SWITCHING

*Note: Older installations designed prior to BS7671:2008 may not have been provided with RCDs for additional protection

Isolators		
Presence and condition of appropriate devices •		✓
Acceptable location - state if local or remote from equipment in question •		✓
Capable of being secured in the OFF position •		✓
Correct operation verified •		✓
Clearly identified by position and / or durable marking •		✓
Warning label posted in situations where live parts cannot be isolated by the operation of a single device •		✓
Switching off for mechanical maintenance		
Presence and condition of appropriate devices •		✓
Acceptable location - state if local or remote from equipment in question •		✓
Capable of being secured in the OFF position •		✓
Correct operation verified •		✓
Clearly identified by position and / or durable marking •		✓

Reference Number:

EICRCOUNTYBRIDGE001

Inspection Schedule (5)

8 - ISOLATION AND SWITCHING (Continued)

Emergency switching / stopping

- Presence and condition of appropriate devices
- Readily accessible for operation where danger might occur
- Correct operation verified
- Clearly identified by position and / or durable marking

Comments

Outcome

✓

✓

✓

✓

Functional Switching

- Presence and condition of appropriate devices
- Correct operation verified

✓

✓

9 - CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)

- Condition of equipment in terms of IP rating etc
- Equipment does not constitute a fire hazard
- Enclosure not damaged / deteriorated so as to impair safety
- Suitability for the environment and external influences
- Security of fixing
- Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page)

✓

✓

✓

✓

✓

✓

Recessed luminaires (downlighters)

- Correct type of lamps fitted
- Installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar
- No signs of overheating to surrounding building fabric
- No signs of overheating to conductors / terminations

✓

✓

✓

✓

10 - LOCATION(S) CONTAINING A BATH OR SHOWER

- Additional protection for all low voltage (LV) circuits by RCD not exceeding 30mA
- Where used as a protective measure, requirements for SELV or PELV met
- Shaver sockets comply with BS EN 61558-2-5 formerly BS3535
- Presence of supplementary bonding conductors, unless not required by BS7671:2008
- Low voltage (e.g. 230 volt) socket-outlets sited at least 3m from zone 1
- Suitability of equipment for external influences from installed location in terms of IP rating
- Suitability of equipment for installation in a particular zone
- Suitability of current-using equipment for particular position within the location

✓

✓

N/A

✓

✓

✓

✓

✓

11 - SPECIAL INSTALLATIONS OR LOCATIONS If any special installations or locations are present, list the particular inspections applied on a separate sheet.

Inspected by:

Name:

A SOUTH

Date:

24/06/2019

Position:

ENGINEER

Signature:



Reference Number:

EICRCOUNTYBRIDGE001

Circuit Details

DB Reference:

DB1

DB Location:

MAIN INTAKE ROOM

Distribution Board Comments:

Supplied from:

DNO

Overcurrent Device:

60947

RCD Operating Current:

N/A

Board Manufacturer:

MEM SHIED 2

Device Rating:

200

RCD time delay:

RCD Operating time at I_{Δn}

N/A

Circuit Details

Circuit Number

Circuit Description

Circuit Category

Number of points served
Disconnection Time (s)
Device BS (EN)
Device Type
Device Rating (A)
Device Breaking Capacity (kA)
RCD Operating Current (mA)
Maximum Permitted Z_s (Ω)
Type of Wiring
Installation Method*
Live csa (mm²)
Cpc csa (mm²)

*Codes for installation methods

- A. In conduit in thermally insulated wall
- B. In conduit on a wall or in trunking
- C. Clipped direct
- D. Direct buried or in ducting or conduit in ground
- E & F. In free air or on cable tray or ladder touching
- G. In free air on cable tray or ladder spaced
- Twin & Earth cable only:
- 100. Above plasterboard ceiling, insulation <100mm
- 101. Above plasterboard ceiling, insulation >100mm
- 102. Insulated stud wall, touching inner wall
- 103. Insulated stud wall, not touching inner wall

L1	SOCKETS THIS ROOM	Ring Circuit	0.4	61009	B	32	1	30	1.3656	A	B	2.5	1.5
L2	SUB MAIN (DB5)	Radial Circuit	5	60898	C	63	1	N/A	0.3468	G	C	16	16
L3	SUB MAIN (DB3)	Radial Circuit	5	60898	C	63	1	N/A	0.3468	G	C	16	16
2L1	SUB MAIN (DB2)	Radial Circuit	5	60898	C	63	1	N/A	0.3468	G	C	16	16
L2	"												
L3	"												
3L1	SUB MAIN (DB4)	Radial Circuit	5	60898	C	63	1	N/A	0.3468	G	C	16	16
L2	SPUR FIRE ALARM	Radial Circuit	0.4	60898	B	16	1	N/A	2.7312	O	B	2.5	1.5
L3	BOILER CONTROL PANEL	Radial Circuit	5	60898	C	63	1	N/A	0.3468	G	C	16	16
4L1	SPUR DISABLED ALARM	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	2.5	1.5
L2	REAR CANOPY	Radial Circuit	0.4	60898	C	16	1	N/A	1.3656	A	B	2.5	1.5
L3	SPARE												
5L1	SPURS ROLLER SHUTTERS	Radial Circuit	0.4	60898	B	32	1	N/A	1.3656	A	B	2.5	1.5
L2	SPARE												
L3	SPARE												
6L1	SOCKETS ENTRANCE, STAFFROOM AND CLEANERS	Ring Circuit	0.4	60898	B	32	1	N/A	1.3656	A	B	2.5	1.5
L2	SPARE												
L3	SPARE												
7L1	SOCKETS OFFICE	Ring Circuit	0.4	60898	B	32	1	N/A	1.3656	A	B	2.5	1.5
L2	SPARE												
L3	SPARE												
8L1	LIGHTS THIS ROOM	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	2.5	1.5
L2	SPARE												
L3	SPARE												

Codes for type of wiring:

A PVC/PVC Cables

B PVC Cables in metallic conduit

C PVC Cables in non-metallic conduit

D PVC Cables in metallic trunking

E PVC Cables in non-metallic trunking

F PVC/SWA Cables

G XLPE/SWA Cables

H Mineral Insulated cables



Reference Number:

EICRCOUNTYBRIDGE001

DB Reference:


DB1

DB Location:

MAIN INTAKE ROOM

Test Results

ORIGINAL

Tested by:		Name: A SOUTH		Test instrument serial numbers:		Continuity: M-1 800464		Earth electrode resistance:		Details of circuits and/or installed equipment vulnerable to damage when testing								
Signature:				RCD: M-1 800464		Earth fault loop impedance:		M-1 800464										
Date: 24/06/2019		Other:		Insulation resistance:		M-1 800464												
Test Results																		
Circuit Number	Ring final circuit continuity (Ω)			Continuity (Ω)			Insulation Resistance (MΩ)			RCD		Distribution Board Characteristics		Circuit Comments				
	R _L (line)	R _N (neutral)	R ₂ (cpc)	R _L + R ₂	R ₂	Live-Live	Live-Neutral	Live-Earth	Neutral-Earth	Polarity	Measured Z _s (Ω)	(ms)	Z _s : .14 Ω		Nominal Voltage: 400 V	No. of phases: 3	Polarity: ✓	Phase rotation: ✓
L1	.63	.64	.81	.39		>200	>200	>200	>200	>200	✓	.53	38	29	✓			
L2				.06		>200	>200	>200	>200	>200	✓	.20						
L3				.06		>200	>200	>200	>200	>200	✓	.20						
2L1				.10		>200	>200	>200	>200	>200	✓	.24						
L2				.10		>200	>200	>200	>200	>200	✓	.24						
L3				.10		>200	>200	>200	>200	>200	✓	.24						
3L1				.07		>200	>200	>200	>200	>200	✓	.21						
L2				.25		>200	>200	>200	>200	>200	✓	.39						
L3				.07		>200	>200	>200	>200	>200	✓	.21						
4L1				.39		>200	>200	>200	>200	>200	✓	.53						
L2				.44		>200	>200	>200	>200	>200	✓	.58						
L3																		
5L1	.86	.86	.99	.45		>200	>200	>200	>200	>200	✓	.61						
L2																		
L3																		
6L1	1.21	1.22	1.40	.13		>200	>200	>200	>200	>200	✓	.37						
L2																		
L3																		
7L1	.14	.14	.22	.05		>200	>200	>200	>200	>200	✓	.19						
L2																		
L3																		
8L1				.61		>200	>200	>200	>200	>200	✓	.75						
L2																		
L3																		

Reference Number:

EICRCOUNTYBRIDGE001

Circuit Details

DB Reference:

DB 1 CONT

DB Location:

MAIN INTAKE ROOM

Distribution Board Comments:

Supplied from:

DNO

Overcurrent Device:

60947

RCD Operating Current:

N/A

Board Manufacturer:

MEM

Device Rating:

200

RCD time delay:

A

RCD Operating time at I_{pn}

N/A

ms

Circuit Details

Circuit Number

Circuit Description

Circuit Category

Number of points served

Disconnection Time (s)

Device BS (EN)

Device Type

Device Rating (A)

Device Breaking Capacity (kA)

RCD Operating Capacity (mA)

Maximum Permitted Z_s (Ω)

Type of Wiring

Installation Method*

Live csa (mm²)

Cpc csa (mm²)

*Codes for installation methods

A. In conduit in thermally insulated wall

B. In conduit on a wall or in trunking

C. Clipped direct

D. Direct buried or in ducting or conduit in ground

E & F. In free air or on cable tray or ladder touching

G. In free air on cable tray or ladder spaced

Twin & Earth cable only:

100. Above plasterboard ceiling, insulation <100mm

101. Above plasterboard ceiling, insulation >100mm

102. Insulated stud wall, touching inner wall

103. Insulated stud wall, not touching inner wall

9L1	LIGHTS WC'S	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	1.5	1	
L2	SPARE													
L3	SPARE													
10L1	LIGHTS STAFF AND OFFICE	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	1.5	1	
L2	SPARE													
L3	SPARE													
11L1	LIGHTS DISABLED WC	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	1.5	1	
L2	"													
L3	"													
12L1	SPUR INTRUDER ALARM	Radial Circuit	0.4	60898	B	16	1	N/A	2.7312	A	B	2.5	1.5	
L2	"													
L3	"													
13L1	SPUR TV AMP	Radial Circuit	0.4	60898	B	16	1	N/A	2.7312	A	B	1.5	1	
L2	"													
L3	"													
14L1	SOCKETS BESIDE DB	Radial Circuit	0.4	60898	C	32	1	N/A	0.6828	A	B	2.5	1.5	
L2	SPARE													
L3	"													
15L1	"													
L2	"													
L3	"													
16L1	"													
L2	"													
L3	"													

Codes for type of wiring:

A PVC/PVC Cables

B PVC Cables in metallic conduit

C PVC Cables in non-metallic conduit

D PVC Cables in metallic trunking

E PVC Cables in non-metallic trunking

F PVC/SWA Cables

G XLPE/SWA Cables

H Mineral Insulated cables



ORIGINAL

Reference Number:

EICRCOUNTYBRIDGE001

Test Results


DB Reference:

DB 1 CONT

DB Location:

MAIN INTAKE ROOM

ORIGINAL

Tested by:		Name: A SOUTH		Test instrument serial numbers:		Continuity: M-1 800464		Earth electrode resistance:		Details of circuits and/or installed equipment vulnerable to damage when testing							
Signature:				RCD: M-1 800464		Earth fault loop impedance:		M-1 800464									
Date: 24/06/2019		Other:		Insulation resistance:		M-1 800464											
Test Results																	
Circuit Number	Ring final circuit continuity (Ω)			Continuity (Ω)			Insulation Resistance (MΩ)			RCD		Distribution Board Characteristics					
	R _L (line)	R _n (neutral)	R ₂ (cpc)	R _L + R ₂	R ₂	Live-Live	Live-Neutral	Live-Earth	Neutral-Earth	Polarity	Measured Z _s (Ω)	(ms)	Z _s : .14 Ω	Nominal Voltage: 400 V	No. of phases: 3	Polarity: ✓	Phase rotation: ✓
9L1			.70			>200	>200	>200	✓	.84							
L2																	
L3																	
10L1			.58			>200	>200	>200	✓	.72							
L2																	
L3																	
11L1			.04			>200	>200	>200	✓	.18							
L2																	
L3																	
12L1			.07			>200	>200	>200	✓	.21							
L2																	
L3																	
13L1			.04			>200	>200	>200	✓	.18							
L2																	
L3																	
14L1			.03			>200	>200	>200	✓	.17							
L2																	
L3																	
15L1																	
L2																	
L3																	
16L1																	
L2																	
L3																	

Reference Number:

EICRCOUNTYBRIDGE001

Circuit Details

DB Reference:

DB 2

DB Location:

MAIN KITCHEN

Distribution Board Comments:

Supplied from:

DB1 C2 TP

Overcurrent Device:

60898 C

RCD Operating Current:

N/A

Board Manufacturer:

MEM

Device Rating:

63

A delay:

RCD time

RCD Operating time at I_{pn}

N/A

ms

Circuit Details

Circuit Number

Circuit Description

Circuit Category

Number of points served
Disconnection Time (s)
Device BS (EN)

Device Type
Device Rating (A)
Device Breaking Capacity (kA)

RCD Operating Current (mA)
Maximum Permitted Z_s (Ω)
Type of Wiring

Installation Method*
Live csa (mm²)
Cpc csa (mm²)

*Codes for installation methods

- A. In conduit in thermally insulated wall
B. In conduit on a wall or in trunking
C. Clipped direct
D. Direct buried or in ducting or conduit in ground
E & F. In free air or on cable tray or ladder touching
G. In free air on cable tray or ladder spaced
- Twin & Earth cable only:
100. Above plasterboard ceiling, insulation <100mm
101. Above plasterboard ceiling, insulation >100mm
102. Insulated stud wall, touching inner wall
103. Insulated stud wall, not touching inner wall

1L1 SOCKETS HIGH LEVEL (CONTACTOR)

L2 CONTACTOR SUPPLY

L3 LIGHTS KITCHEN

2L1 SOCKETS KITCHEN

L2 EXTRACTOR FAN

L3 EXTRACTOR FAN WCS

3L1 DISHWASHER (CONTACTOR)

L2 "

L3 "

4L1 SPARE

L2 "

L3 "

5L1 "

L2 "

L3 "

6L1 "

L2 "

L3 "

L2 "

L3 "

L2 "

L3 "

L2 "

L3 "

L2 "

L3 "

L2 "

L3 "

Codes for type of wiring:

A PVC/PVC Cables

B PVC Cables in metallic conduit

C PVC Cables in non-metallic conduit

D PVC Cables in metallic trunking

E PVC Cables in non-metallic trunking

F PVC/SWA Cables

G XLPE/SWA Cables

H Mineral Insulated cables



Reference Number:

EICRCOUNTYBRIDGE001

DB Reference:

DB 2

DB Location:

MAIN KITCHEN

Test Results

Tested by:

Name:

A SOUTH

Signature:



Date:

24/06/2019

Test instrument serial numbers:

Continuity:

M-1 800464

RCD:

M-1 800464

Other:

Earth electrode resistance:

M-1 800464

Earth fault loop impedance:

M-1 800464

Insulation resistance:

M-1 800464

Details of circuits and/or installed equipment vulnerable to damage when testing

Test Results

Circuit Number

R_f (line)

R_n (neutral)

R_2 (pc)

$R_f + R_2$

R_2

Live-Live

Live-Neutral

Live-Earth

Neutral-Earth

Polarity

Measured Z_s (Ω)

@ 1In

@ 5In

(ms)

Test Button Operation

RCD

Distribution Board Characteristics

Z_s : .24 Ω

I_{pf} : 1.05 kA

Nominal Voltage: 400 V

No. of phases: 3

Polarity: ☒

Phase rotation: ☒

Circuit Comments

E/CRC/COUNTYBRIDGE001

DB Reference:

DB Location:

SMALL KITCHEN

Supplied from:	DB1 1/1.3	Overcurrent Device:	60898	C	RCD Operating Current:	N/A
Board Manufacturer:	MEM	Device Rating:	63	RCD time delay:	RCD Operating time at I _{Δn}	N/A

Circuit Number

*Codes for installation methods

A. In conduit in thermally insulated wall

Twin & Earth cable only:

B. In conduit on a wall or in trunking

100. Above plasterboard ceiling, insulation <100mm

C. Clipped direct

101. Above plasterboard ceiling, insulation > 100mm

D. Datté, maître de la sculpture de la cathédrale de Strasbourg

102. Insulated stud wall, touching inner wall

G. In free air on cable tray or ladder spaced

1000

[illegible]

ORIGINAL

EICRCOUNTYBRIDGE001

DB Reference:

DB Location:

SMALL KITCHEN

DB Reference:

DB Location:

SMALL KITCHEN

SHORTING BAR FITTED ACROSS PHASES TO MAKE

3 PHASE BOARD A SINGLE PHASE

Supplied from:

DB1 L/2

Overcurrent Device:

60

C 898

RCD Operating Current:

N/A	mA
-----	----

Board Manufacturers:

MEM

Device Rating:

63

A RCD delay:

me

100

RCD Open
time at 1 an

ating

N/A	ms
-----	----

Circuit Details		*Codes for Installation methods A. In conduit in thermally insulated wall B. In conduit on a wall or in trunking C. Clipped direct D. Direct buried or in ducting or conduit in ground E & F. In free air or on cable tray or ladder touching G. In free air on cable tray or ladder spaced																	
Circuit Number		Circuit Description	Circuit Category	Number of points served												Live csa (mm²)		Cpc csa (mm²)	
				Disconnection Time (s)		Device BS (EN)		Device Type		Device Rating (A)		RCD Operating Capacity (kA)		Maximum Permitted Zs (Ω)		Installation Method*			
1L2	SPUR OVER DOOR HEATER LOBBY	Radial Circuit	0.4	60898	B	32	1	N/A	1.3656	A	B	4	1.5						
2L2	SOCKETS LOBBY	Ring Circuit	0.4	60898	B	32	1	N/A	1.3656	A	B	2.5	1.5						
3L2	SOCKETS COMMITTEE ROOM	Ring Circuit	0.4	60898	B	32	1	N/A	1.3656	A	B	2.5	1.5						
4L2	SPARE		0.4	60898	B	32	1	N/A	1.3656										
5L2	SPARE		0.4	60898	C	32	1	N/A	0.6828										
6L2	SOCKETS MAIN ROOM ALCOVE	Ring Circuit	0.4	60898	C	32	1	N/A	0.6828	A	B	2.5	1.5						
7L2	SOCKETS SMALL KITCHEN	Ring Circuit	0.4	60898	B	32	1	N/A	1.3656	A	B	2.5	1.5						
8L2	EXTRACT FANS WC	Radial Circuit	0.4	60898	B	16	1	N/A	2.7312	A	B	1.5	1						
9L2	SPARE																		
10L2	LIGHTS ENTRANCE LOBBY	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	1.5	1						
11L2	LIGHT BOYS AND GIRLS WC'S	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	1.5	1						
12L2	LIGHTS	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	1.5	1						
13L2	LIGHTS	Radial Circuit	0.4	60898	B	10	1	N/A	4.37	A	B	1.5	1						
14L2	SPUR ROLLER SHUTTERS	Radial Circuit	0.4	60898	B	20	1	N/A	2.185	A	B	2.5	1.5						
15L2	SPARE		0.4	60898	B	20	1	N/A	2.185										
16L2	SPURS CCTV	Radial Circuit	0.4	60898	B	20	1	N/A	2.185	A	B	2.5	1.5						
17L2	SPURS CCTV	Radial Circuit	0.4	60898	B	20	1	N/A	2.185	A	B	2.5	1.5						
18L2	SPARE																		
19L2	SPARE																		
20L2	SPARE																		
21L2	SPARE																		
22L2	SPARE																		
Codes for type of wiring:																			
A		PVC/PVC Cables																	
B		PVC Cables in metallic in non-metallic in non-metallic conduit																	
C		PVC Cables in non-metallic in metallic in non-metallic conduit																	
D		PVC Cables in non-metallic in metallic in non-metallic trunking																	
E		PVC Cables in non-metallic in metallic in non-metallic trunking																	
F		PVC/SWA Cables																	
G		XLPE/SWA Cables																	
H		Mineral Insulated cables																	

ORIGINAL

EICRCOUNTYBRIDGE001

DB Reference:

DB Location:

MAIN KITCHEN

Distribution Board Comments:

Supplied from:

DB1 3L1

Overcurrent Device:

60898 C

RCD Operating Current:

N/A	MA
-----	----

Board Manufacturer:

MEM

Device Rating:

63

RCD delay: A

⑤

RCD Operating
time at 1 an

N/A	ms
-----	----

*Codes for installation methods

A. In conduit in thermally insulated wall

Twin & Earth cable only:

B. In conduit on a wall or in trunking

100. Above plasterboard ceiling, insulation <100mm

C. Clipped direct

101. Above plasterboard ceiling, insulation >100mm

D. Direct burial or incurring of cost in ground

102. Insulated stud wall, touching inner wall

Let's see all of the ways of making

100. Insulated steel wall, not touching interior wall.

0. 11100 all 011 00010 "day of natural operations"

[illegible]

This form is based on the model shown in Appendix 6 of BS7671:2008 amended 2015. Generated by Castline Systems FormFill software. © Jan 2015.

ORIGINAL

ELECTRICAL INSTALLATION CONDITION REPORT GUIDANCE FOR RECIPIENTS

This Report is an important and valuable document which should be retained for future reference.

The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section 4). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger.

The person ordering the Report should have received the “original” Report and the inspector should have retained a duplicate.

The “original” Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested quarterly. For safety reasons it is important that this instruction is followed.

Section 3 (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in section 3 - Extent and Limitations on page 1.

For items classified in the observations as C1 (“Danger present”), the safety of those using the installation is at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in the observations as C2 (“Potentially dangerous”), the safety of those using the installation may be at risk and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated that an observation requires further investigation the inspection has revealed an apparent deficiency which may result in a Code 1 or Code 2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section 7 - Recommendations).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated on page 2 of the Report under ‘Recommendations’ and on a label at or near to the consumer unit / distribution board.